SIEMENS

Data sheet 6AV2125-2AE23-0AX0

SIMATIC HMI connection box Advanced for Mobile Panels, wall mounting, PROFINET and PROFIsafe, connection of safety relay, emergency stop circuit bridging, terminal detection, Integrated switch, MRP client, IRT

General information	
Product type designation	Connection box
Product function	
● Web-based management	Yes
FH technology	
Safety evaluation through direct wiring	
● Reconnection without emergency stop circuit interruption	Yes
● Reconnection with emergency stop circuit interruption	No
● Monitoring the STOP button	Yes
● Monitoring of emergency stop button	Yes
● Monitoring of acknowledgement button	Yes
Safety evaluation via PROFIsafe	
● Reconnection without emergency stop circuit interruption	Yes
● Reconnection with emergency stop circuit interruption	No
● Monitoring the STOP button	Yes
● Monitoring of emergency stop button	Yes
● Monitoring of acknowledgement button	Yes
Installation type/mounting	
Wall mounting/direct mounting	Yes
Control cabinet installation	No
Supply voltage	
Type of supply voltage	DC
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Input current	
Current consumption (rated value)	95 mA
Starting current inrush I²t	0.16 A²·s
Power	
Active power input, typ.	2.3 W
Interfaces	
Number of industrial Ethernet interfaces	3
Number of PROFINET interfaces	3
Connection point identification	Yes
Industrial Ethernet	
● Industrial Ethernet status LED	3
Protocols	
PROFINET	Yes
IRT	Yes

Subject to change without notice
© Copyright Modulplc

PROFIsafe	Yes
EtherNet/IP	Yes
AS-Interface	No
EIB/KNX	No
Protocols (Ethernet)	
● TCP/IP	Yes
● DHCP	Yes
● SNMP	Yes
● DCP	Yes
● LLDP	Yes
Redundancy mode	
Media redundancy	
— MRP	Yes
Further protocols	
● MODBUS	Yes
● other bus systems	No
EMC	
Emission of radio interference acc. to EN 55 011	
● Limit class A, for use in industrial areas	No
● Limit class B, for use in residential areas	No
Degree and class of protection	
IP degree of protection	IP65
IP65 (all-round)	Yes
IP (at the front)	IP65
Standards, approvals, certificates	
CE mark	Yes
cULus	Yes
RCM (formerly C-TICK)	Yes
KC approval	No; in preparation
Suitable for safety functions	Yes
Highest safety class achievable in safety mode	
● Performance level according to ISO 13849-1	PLe
● SIL acc. to IEC 61508	SIL 3
Use in hazardous areas	
● ATEX Zone 2	No
● ATEX Zone 22	No
● cULus Class I Zone 1	No
● cULus Class I Zone 2, Division 2	No
● FM Class I Division 2	No
Marine approval	
● Germanischer Lloyd (GL)	Yes
● American Bureau of Shipping (ABS)	Yes
● Bureau Veritas (BV)	Yes
● Det Norske Veritas (DNV)	Yes
● Korean Register of Shipping (KRS)	Yes
● Lloyds Register of Shipping (LRS)	Yes
● Nippon Kaiji Kyokai (Class NK)	Yes
● Polski Rejestr Statkow (PRS)	No
● Chinese Classification Society (CCS)	Yes
Ambient conditions	
Ambient temperature during operation	
● min.	0 °C
● max.	55 °C
Relative humidity	
● Operation, max.	90 %
Configuration	
Configuration software	
● STEP 7 Professional (TIA Portal)	No
● WinCC Comfort (TIA Portal)	Yes; Optional

© Copyright Modulplc

● WinCC Advanced (TIA Portal)	Yes; Optional
● WinCC Professional (TIA Portal)	Yes; Optional
Mechanics/material	
Enclosure material (front)	
● Plastic	Yes
● Aluminum	No
● Stainless steel	No
Dimensions	
Width	230 mm
Height	151.3 mm
Depth	75.4 mm
Weights	
Weight (without packaging)	0.72 kg
Weight (with packaging)	0.8 kg

Classifications

	Version	Classification
eClass	16	27-33-02-92
eClass	14	27-33-02-92
eClass	12	27-33-02-92
eClass	9.1	27-33-02-92
eClass	9	27-33-02-92
eClass	8	27-24-92-03
eClass	7.1	27-24-92-03
eClass	6	27-24-92-03
ETIM	10	EC002584
ETIM	9	EC002584
ETIM	8	EC002584
ETIM	7	EC002584
IDEA	4	3552
UNSPSC	15	32-15-17-03

Approvals / Certificates

General Product Approval

Miscellaneous | Manufacturer Declaration

General Product Approval | **EMV** | **Functional Saftey**

China RoHS | TUEV | TUEV

Functional Saftey | **Maritime application**

Type Examination Certificate

Maritime application | **other**

© Copyright Modulplc

CCS (China Classification Society) KR (Korean Register of Shipping) Type Examination Certificate

last modified: 2/4/2025

© Copyright Modulplc